Heraeus



Treated with Heraeus long life technology

Conventional coating




Quartz

Longlife Technology Doubles the Efficiency of High Power Amalgam Lamps

Lifetime dependency of coating

UVC radiation has an intense bactericidal action. Microorganisms such as viruses, bacteria, yeasts and spores are effectively inactivated without the addition of chemicals. The energy of UVC radiation is sufficient to break down chemical compounds or to achieve molecular restructuring. In addition, oxidation processes and decomposition reactions of organic compounds are initiated.

Amalgam UVC lamps with Longlife Technology offer a disinfection action which is virtually constant over the lamp operating life. While the UVC output of uncoated lamps drops by around 50% after 8,000 hours, the Amalgam UVC lamps with Longlife Technology have a reduction in UVC output of approximately 10% at up to 16,000 hours.



Influence on quartz transmission


Because of the higher UVC output at end of lamp life due to minimal absorption and the extended operating life, Heraeus Longlife Amalgam lamps offer disinfection systems a significant potential for savings. The benefits are fewer lamps and system consumables, less energy consumption and maintenance costs.

Compared with standard low pressure mercury lamps, the amalgam lamps offer the extremely good UVC efficiency, which is typical of mercury low pressure lamps, but with a significantly higher UVC output.

With Longlife Technology, lamps can be produced which have no discoloration and even after 16,000 hours still provide a UVC output greater than 90% of the original output.

Technical data of compared lamps

Heraeus Amalgam lamps offer great potential for savings in number of lamps, system components, energy consumption and service intervals – while significantly reducing the operating costs of disinfection systems.



The comparison below shows an example of different lamp types and their consumption over six years. Based on the same demand for UVC output, different numbers of lamps per system are needed.

				0	0			Initial UVC efficiency			UVC efficiency @ end of life		
Lamp typ	ie .	Lam	ıps/system	u ua	ntity of lan	ips	Initial UV	C efficien	cy U	VC etticien	cy @ ena (ot lite	
Heraeus Longlife Amalgam Lamp		Lamp	5	15 lamps in 48,000 h			35 %			32 %			
Operation hours	;												
0 h	4,000 h	8,000 h	12,000 h	16,000 h	20,000 h	24,000 h	28,000 h	32,000 h	36,000 h	40,000 h	44,000 h	48,000	
Lamp change													
Amalgam Lamp with conventional coating			6	24 lamps in 48,000 h		31 %		24 %					
Operation hours	;												
0 h	4,000 h	8,000 h	12,000 h	16,000 h	20,000 h	24,000 h	28,000 h	32,000 h	36,000 h	40,000 h	44,000 h	48,000	
Lamp change													
Conventional Amalgam Lamp			10	60 lamps in 48,000 h			35 %			18 %			
Operation hours	;												
0 h	4,000 h	8,000 h	12,000 h	16,000 h	20,000 h	24,000 h	28,000 h	32,000 h	36,000 h	40,000 h	44,000 h	48,000	
Lamp change													

www.heraeus-noblelight.com

Germany

Heraeus Noblelight GmbH

Heraeusstraße 12–14 63450 Hanau Phone +49 6181 35-5964 Telefax +49 6181 35-9926 hng-uv@heraeus.com Great Britain

Heraeus Amba Ltd.

Thorpe Way
Banbury 0X16 4ST
Phone +44 1295 272666
Telefax +44 1295 272611
ambalamps@heraeusamba.co.uk

USA

Heraeus Noblelight Fusion UV Inc.

910 Clopper Road
Gaithersburg, Maryland
Gaithersburg, Maryland
Phone + 1 301 527 2260
Telefax + 1 301 527 2661
info.hnfn@noblelight.com

China

5F, 16th Builing

Heraeus Noblelight (Shenyang). Ltd.

No.99 TianZhou Rd. 200233 Shanghai Phone +86 21 54263900-258 Telefax +86 21 54263911 info.hns@heraeus.com

